

- NOTES:
1. FOUNDATION SHALL BE OF CLASS "C" CONCRETE, AND MAY BE PRECAST.
 2. ONE (1) SWEEP SHALL BE ON THE EXTERIOR AND DEDICATED FOR THE UTILITY CO. POWER FEED.
 3. ALL SWEEPS SHALL BE 2" DIA. P.V.C. CONDUIT.




TOWN OF WINDSOR
Engineering Department



STREET LIGHT CONTROLLER
FOUNDATION

D-404



SCALE: HOR. NTS DATE: AUGUST 2008
VER.